

Judith Evans, FRPERC, University of Bristol

Energy savings in cold storage




Cold stores – main issues


- Energy large proportion of costs (~60%)
- Recent large increases in energy costs
- Large variations in energy efficiency
- Awareness of global warming, reduction in CO₂ emissions




Cold stores - chilled



Cold stores - frozen




Cold stores - mixed



kWh/m³/yr


Chilled




Food Refrigeration & Process Engineering Research Centre




Frozen



Mixed



Heat loads



1. Conduction
2. Infiltration
3. Fans
4. Food
5. Lighting
6. Machinery
7. People
8. Radiation

Energy saving

- **Reduce heat loads from**
 - **Food**
 - **Room structure**
 - **Infiltration**
- **Optimisation/design of refrigeration system**
- **Operation of refrigeration system**
- **Operation of fans**
- **Choice of equipment**
- **Maintenance**
- **Free cooling/heat recovery**

Examples of energy reduction in cold stores

1. R22 DX plants

- All heat loads on store + refrigeration system

2. Poorly maintained R717 plant

- Refrigeration system optimisation only

3. Well maintained R717 plant

- Refrigeration system optimisation only

Example 1


Store	Rooms	Size (m ²)	Refrigeration system
1	3 frozen chambers	1550	DX, single stage compression, evaporative condensers, R22
2	1 frozen chamber	910	LP receiver, twin screw economised compressor, R22
3	3 chilled/frozen chambers	2458	DX, single stage compression, evaporative condensers, R22

Example 1. Data collected


- **Store temperature (air-on, air-off, simulated product)**
- **Refrigeration system temperatures**
- **Door openings**
- **Food entry/exit – quantity and temperature**
- **People and machinery entry/exit**
- **Energy consumption (every 30 minutes)**
- **Meteorological data**
- **Performance data on refrigeration system components, store construction**



Example 1. Results – heat loads



Example 1. Heat load across insulation



**8" (203 mm)
reduced by 35%**


**10" (245 mm)
reduced by 47%**

**13" (330 mm)
reduced by 64%**

Example 1. Fixed loads

- Pulsing fans
- Increased load shedding
- Defrost optimisation
 - Off-cycle in chillers (40,000 kWh per year in store 3)
 - Optimisation of settings

Example 1. Infiltration



47 - 59% reduction
in heat load by
fitting PED and
improving door
protection

Example 1. Efficiency of refrigeration plant

Refrigeration plant	Energy used to remove 1kW of heat from the evaporator (kW)
Cold store 1	0.66-1.07
Cold store 2	0.79
Cold store 3	1.09 (frozen), 1.02-1.10 (chilled)

Operated at -14°C (others -22°C)

Operated at -22°C, LP receiver, fully flooded

Not optimised for chillers

Plant set for -22°C ran in summer at -20°C

Stores 1 and 3 head pressure control – LP amplification would allow head pressure to float

All plant except 2 ran with high superheat, SLHE increase useful area of evaporator

Example 1. Options to improve

	Store 1 (F)	Store 2 (F)	Store 3 (F/C)
Size (m ³)	1550	910	2458
	kWh/m ³ /yr		
Current	59	91	52
Pedestrian doors	53	85	50
Rapid rolls doors/improved strip curtains	52	82	49
Defrost optimisation	58	91	49
Off-cycle defrost			51
Separate entrance to store	51		
Automatic closing door	57		
Preventing door being jammed open		88	
Suction liquid heat exchangers	56		44
Liquid pressure amplification	49		38
Evaporative condensers	58	56	
Low pressure receiver (lpr)	40		32
Improve insulation on walls to 10"	51	86	46
Reduce the speed and off load compressor			50
Potential saving from best technology	>32%	>38%	>38%
Potential achievable by updating current	>14%	>10%	>15%

Best mixed = 27 kWh/m³/yr (best savings = 32 kWh/m³/yr)

Best freezer = 48 kWh/m³/yr (best savings = 40/56 kWh/m³/yr)

Energy savings achieved

- **Not all improvements carried out (long payback periods)**
 - **PED doors**
 - **Rapid roll doors**
 - **LPA**
 - **SLHE**
 - **Evaporative condenser**
- **Should have achieved 17.3% reduction in energy if implemented all above improvements**
- **Achieved 9.4%**



Example 2

- **2 large cold store plants**
- **Store 1+blast freezer**
- **Stores 2+3 freezers**
- **Ammonia, 2 stage compression, pump recirculation system**
- **35 years old**



Example 2. Cold stores - options to improve



Maintenance

	Store 1+blast freezer (F/C)	Store 2+3 (F)
Size (m ³)	12,399	7,347
	kWh/m ³ /yr	
Current	88	79
Increase load, operate plant for shorter periods	84	78
Adjust surge drum and intercooler pressures to loads	85	79
Clear evaporators of ice, repair defrost timers	86	78
Overhaul compressors	61	76
Repair hot gas valve	87	n/a
Repair PRV in ammonia pumps	86	78
Reinsulate pipes to plant	76	74
Reinsulate surge drum	86	79
Potential saving from better maintenance	10-60%	3-16%

n.b. Only refrigeration, potential additional savings from operation and heat loads

Best mixed = 27 kWh/m³/yr (best savings = 61 kWh/m³/yr)

Best freezer = 48 kWh/m³/yr (best savings = 74 kWh/m³/yr)

Example 3

- **2 large cold store plants**
- **Store 1 freezer (2 rooms)**
- **Store 2 freezer (5 rooms)**
- **Blast freezer**
- **Ammonia, 2 stage compression, pump recirculation system, evaporative condensers**
- **Various ages (20-40 years old)**
- **Well maintained**



Example 3. Cold stores - options to improve



	Store 1 (F)	Store 2 (F/C)	Blast freezer
Size (m ³)	13,925	21,783	4,981
	kWh/m ³ /yr		
Current	30	28	415
1 Reduce condenser pressure	26		
2 Reduce surge drum temperature	36		
1+2	30		
1 Float condenser pressure		25	
2 Increase evaporator temperature		25	
1+2		21	
Fully flooded evaporator, compressor offloading			415 (faster freezing)
Potential saving from better operation	0 (13%)	26%	Better operation

n.b. Only refrigeration, potential additional savings from operation and heat loads


Best mixed = 27 kWh/m³/yr (best savings = 21 kWh/m³/yr)

Best freezer = 48 kWh/m³/yr (best savings = 30 kWh/m³/yr)

Target and monitoring



Useful method to take charge of energy usage



Leakage



- Contribution to global warming
- Leakage
 - Lack of detailed information 7-10% (UNEP, 2003)
 - May be higher 17% (Clodic and Palandre, 2004)
- Cold stores – R22 (15-20%), R717 (60-70% of industrial refrigeration)
- Lower leakage of R717 due to pungent smell
- R22 is an HCFC – being phased out from 2010
- 15% loss of refrigerant can double energy for a given amount of cooling

GWP	R717	R22	R404A	R134a	R407C	R507	HC	CO ₂
	0	1,700	3,750	1,300	1,980	3,300	0	1

Options to improve

- **Large range in efficiency of current stores**
- **Often varied issues to reduce energy**
- **Potential improvements available, some simple and inexpensive**
- **Identifying improvements not always simple or easy for end users**
- **Data to justify investment in savings not always available**



Further information:

<http://www.frperc.bris.ac.uk/defraenergy/index.html>

Specifically on cold storage:

<http://www.frperc.bris.ac.uk/defraenergy/storage.html>



Storage

Site Location: [Home](#) > **Storage**

- [Home](#)
- [About this project](#)
- [Sectoral focus reports](#)
- [Top 10 energy users](#)
- [Supply network](#)
- [Maintenance](#)
- [Events](#)
- [Join stakeholders group](#)
- [Links](#)
- [Downloads](#)
- [Contact us](#)

Reports on the refrigeration energy usages in Storage can be downloaded from this page, the [sectoral focus page](#), or the [downloads page](#)

- [Frozen storage - generic](#)
- [Potato storage - bulk raw potatoes](#)

Chilled and frozen cold storage and distribution operations have been identified as major users of energy.

Investigations at three UK cold storage complexes demonstrated significant opportunities for energy savings. At least 30% in the 5 stores examined. Options to reduce energy in 3 direct expansion refrigeration system stores and 2 ammonia stores were identified and quantified.

